

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7270-0026:200

Page 1 of 1

CATEGORY: Heat Detector

LISTEE: Simplex, 100 Simplex Drive, Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-8542 *FAX (978) 731-8881

DESIGN: Models 4098-9401, -9402, -9403, -9404, -9407, -9408, -9409, and -9410 heat detectors.
Refer to listee's data sheet for detailed product description and operational considerations.

RATING:	<u>Model</u>	<u>Rating (°F)</u>	<u>Type</u>
	-9401/-9407	135	Fixed Temp/Rate Compensated
	-9402/-9408	135	Fixed Temp/Rate of Rise
	-9403/-9409	200	Fixed Temp/Rate Compensated
	-9404/-9410	200	Fixed Temp/Rate of Rise

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical/temperature ratings and UL label.

APPROVAL: Listed as system heat detectors for use with separately listed compatible bases and control units.

*Rev. 05-12-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 17, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**